

MANUAL

Functional Safety

SMART Transmitter Power Supply

HiD2022*, KFD2-STC5-(Ex)*,
KFD2-STV5-(Ex)*



With regard to the supply of products, the current issue of the following document is applicable: The General Terms of Delivery for Products and Services of the Electrical Industry, published by the Central Association of the Electrical Industry (Zentralverband Elektrotechnik und Elektroindustrie (ZVEI) e.V.) in its most recent version as well as the supplementary clause: "Expanded reservation of proprietorship"

1	Introduction	4
1.1	Contents	4
1.2	Safety Information	5
1.3	Symbols Used	6
2	Product Description	7
2.1	Function	7
2.2	Marking	12
2.3	Standards and Directives for Functional Safety	12
3	Planning	13
3.1	System Structure	13
3.2	Assumptions	14
3.3	Safety Function and Safe State	15
3.4	Characteristic Safety Values	17
3.5	Useful Life Time	19
4	Mounting and Installation	20
4.1	Configuration	20
5	Operation	21
5.1	Proof Test Procedure	21
6	Maintenance and Repair	27
7	List of Abbreviations	28

1 Introduction

1.1 Contents

This document contains information for usage of the device in functional safety-related applications. You need this information to use your product throughout the applicable stages of the product life cycle. These can include the following:

- Product identification
- Delivery, transport, and storage
- Mounting and installation
- Commissioning and operation
- Maintenance and repair
- Troubleshooting
- Dismounting
- Disposal

**Note!**

This document does not substitute the instruction manual.

**Note!**

For full information on the product, refer to the instruction manual and further documentation on the Internet at www.pepperl-fuchs.com.

The documentation consists of the following parts:

- Present document
- Instruction manual
- Manual
- Datasheet

Additionally, the following parts may belong to the documentation, if applicable:

- EU-type of examination
- EU declaration of conformity
- Attestation of conformity
- Certificates
- Control drawings
- FMEDA report
- Assessment report
- Additional documents

For more information about functional safety products from Pepperl+Fuchs see www.pepperl-fuchs.com/sil.

1.2 Safety Information

Target Group, Personnel

Responsibility for planning, assembly, commissioning, operation, maintenance, and dismantling lies with the plant operator.

Only appropriately trained and qualified personnel may carry out mounting, installation, commissioning, operation, maintenance, and dismantling of the product. The personnel must have read and understood the instruction manual and the further documentation.

Intended Use

The device is only approved for appropriate and intended use. Ignoring these instructions will void any warranty and absolve the manufacturer from any liability.

The device is developed, manufactured and tested according to the relevant safety standards.

Use the device only

- for the application described
- with specified environmental conditions
- with devices that are suitable for this safety application

Improper Use

Protection of the personnel and the plant is not ensured if the device is not used according to its intended use.

1.3 Symbols Used

This document contains symbols for the identification of warning messages and of informative messages.

Warning Messages

You will find warning messages, whenever dangers may arise from your actions. It is mandatory that you observe these warning messages for your personal safety and in order to avoid property damage.

Depending on the risk level, the warning messages are displayed in descending order as follows:



Danger!

This symbol indicates an imminent danger.

Non-observance will result in personal injury or death.



Warning!

This symbol indicates a possible fault or danger.

Non-observance may cause personal injury or serious property damage.



Caution!

This symbol indicates a possible fault.

Non-observance could interrupt the device and any connected systems and plants, or result in their complete failure.

Informative Symbols



Note!

This symbol brings important information to your attention.



Action

This symbol indicates a paragraph with instructions. You are prompted to perform an action or a sequence of actions.

2 Product Description

2.1 Function

HiD2022

This isolated barrier is used for intrinsic safety applications.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the safe area as an isolated current value.

Digital signals may be superimposed on the input signal in the hazardous or non-hazardous area and are transferred bi-directionally.

The device provides a source mode output on the safe area terminals.

This device mounts on a HiD Termination Board.

HiD2022SK

This isolated barrier is used for intrinsic safety applications.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the safe area as an isolated current value.

Digital signals may be superimposed on the input signal in the hazardous or non-hazardous area and are transferred bi-directionally.

The device provides a sink mode output on the safe area terminals.

This device mounts on a HiD Termination Board.

KFD2-STC5-1, KFD2-STC5-2

This signal conditioner provides the galvanic isolation between field circuits and control circuits.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal as an isolated current value.

Digital signals may be superimposed on the input signal on the field side or on the control side and are transferred bi-directionally.

The device provides a sink mode or a source mode output on the control side terminals.

The device has an internal resistor. Use this resistor if the HART communication resistance in the control circuit is too low.

Test sockets for the connection of HART communicators are integrated into the terminals of the device.

The device is mounted on a 35 mm DIN mounting rail according to EN 60715.

KFD2-STC5-1.20

This signal conditioner provides the galvanic isolation between field circuits and control circuits.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the control side as two isolated output signals.

Digital signals may be superimposed on the input signal on the field side or on the control side and are transferred bi-directionally.

The device provides a sink mode or a source mode output on the control side terminals.

The device has an internal resistor. Use this resistor if the HART communication resistance in the control circuit is too low.

Test sockets for the connection of HART communicators are integrated into the terminals of the device.

The device is mounted on a 35 mm DIN mounting rail according to EN 60715.

KFD2-STC5-Ex1(.H), KFD2-STC5-Ex2

This isolated barrier is used for intrinsic safety applications.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the safe area as an isolated current value.

Digital signals may be superimposed on the input signal in the hazardous or non-hazardous area and are transferred bi-directionally.

The device provides a sink mode or a source mode output on the safe area terminals.

The device has an internal resistor. Use this resistor if the HART communication resistance in the control circuit is too low.

Test sockets for the connection of HART communicators are integrated into the terminals of the device.

The device is mounted on a 35 mm DIN mounting rail according to EN 60715.

KFD2-STC5-Ex1.20(.H)

This isolated barrier is used for intrinsic safety applications.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the safe area as two isolated output signals.

Digital signals may be superimposed on the input signal in the hazardous or non-hazardous area and are transferred bi-directionally.

The device provides a sink mode or a source mode output on the safe area terminals.

The device has an internal resistor. Use this resistor if the HART communication resistance in the control circuit is too low.

Test sockets for the connection of HART communicators are integrated into the terminals of the device.

The device is mounted on a 35 mm DIN mounting rail according to EN 60715.

KFD2-STV5-1-1, KFD2-STV5-2-1

This signal conditioner provides the galvanic isolation between field circuits and control circuits.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal as an isolated current value.

Digital signals may be superimposed on the input signal on the field side or on the control side and are transferred bi-directionally.

If the HART communication resistance in the loop is too low, the internal resistance can be used.

Test sockets for the connection of HART communicators are integrated into the terminals of the device.

The device is mounted on a 35 mm DIN mounting rail according to EN 60715.

KFD2-STV5-Ex1-1, KFD2-STV5-Ex2-1

This isolated barrier is used for intrinsic safety applications.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the safe area as an isolated current value.

Digital signals may be superimposed on the input signal in the hazardous or non-hazardous area and are transferred bi-directionally.

If the HART communication resistance in the loop is too low, the internal resistance can be used.

Test sockets for the connection of HART communicators are integrated into the terminals of the device.

The device is mounted on a 35 mm DIN mounting rail according to EN 60715.

KFD2-STV5-Ex1.2O-1, KFD2-STV5-Ex1.2O-2

This isolated barrier is used for intrinsic safety applications.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the safe area as two isolated output signals.

Digital signals may be superimposed on the input signal in the hazardous or non-hazardous area and are transferred bi-directionally.

If the HART communication resistance in the loop is too low, the internal resistance can be used.

Test sockets for the connection of HART communicators are integrated into the terminals of the device.

The device is mounted on a 35 mm DIN mounting rail according to EN 60715.

KFD2-STV5-Ex2-1, KFD2-STV5-Ex2-2

This isolated barrier is used for intrinsic safety applications.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the safe area as an isolated current value.

Digital signals may be superimposed on the input signal in the hazardous or non-hazardous area and are transferred bi-directionally.

If the HART communication resistance in the loop is too low, the internal resistance can be used.

Test sockets for the connection of HART communicators are integrated into the terminals of the device.

The device is mounted on a 35 mm DIN mounting rail according to EN 60715.

Interfaces

The device has the following interfaces.

- Safety relevant interfaces:

Input I, output I	KFD2-STC5-1, KFD2-STC5-Ex1, KFD2-STC5-Ex1.H, KFD2-STV5-1-1, KFD2-STV5-Ex1-1, KFD2-STV5-Ex1-2
Input I, output I, output II	KFD2-STC5-1.2O, KFD2-STC5-Ex1.2O, KFD2-STC5-Ex1.2O.H, KFD2-STV5-Ex1.2O-1, KFD2-STV5-Ex1.2O-2
Input I, input II, output I, output II	HiD2022, HiD2022SK, KFD2-STC5-2, KFD2-STC5-Ex2, KFD2-STV5-2-1, KFD2-STV5-Ex2-1, KFD2-STV5-Ex2-2

- Non-safety relevant interfaces: none

The HART communication is not relevant for functional safety.



Note!

For corresponding connections see datasheet.

2.2

Marking

Pepperl+Fuchs GmbH Lilienthalstraße 200, 68307 Mannheim, Germany
Internet: www.pepperl-fuchs.com

HiD2022, HiD2022SK, KFD2-STC5-1, KFD2-STC5-2, KFD2-STC5-Ex1, KFD2-STC5-Ex1.H, KFD2-STC5-Ex2, KFD2-STV5-1-1, KFD2-STV5-2-1, KFD2-STV5-Ex1-1, KFD2-STV5- Ex1-2, KFD2-STV5-Ex2-1, KFD2-STV5-Ex2-2	Up to SIL 2
KFD2-STC5-1.2O, KFD2-STC5-Ex1.2O, KFD2-STC5-Ex1.2O.H, KFD2-STV5-Ex1.2O-1, KFD2-STV5-Ex1.2O-2	Up to SIL 3

2.3

Standards and Directives for Functional Safety

Device specific standards and directives

Functional safety	IEC/EN 61508, part 1 – 7, edition 2010: Functional safety of electrical/electronic/programmable electronic safety-related systems (manufacturer)
-------------------	--

System-specific standards and directives

Functional safety	IEC/EN 61511, part 1 – 3, edition 2003: Functional safety – Safety instrumented systems for the process industry sector (user)
-------------------	--

3 Planning

3.1 System Structure

3.1.1 Low Demand Mode of Operation

If there are two control loops, one for the standard operation and another one for the functional safety, then usually the demand rate for the safety loop is assumed to be less than once per year.

The relevant safety parameters to be verified are:

- the PFD_{avg} value (average **P**robability of dangerous **F**ailure on **D**emand) and the T_1 value (proof test interval that has a direct impact on the PFD_{avg} value)
- the SFF value (**S**afe **F**ailure **F**raction)
- the HFT architecture (**H**ardware **F**ault **T**olerance)

3.1.2 High Demand or Continuous Mode of Operation

If there is only one safety loop, which combines the standard operation and safety-related operation, then usually the demand rate for this safety loop is assumed to be higher than once per year.

The relevant safety parameters to be verified are:

- the PFH value (**P**robability of dangerous **F**ailure per **H**our)
- Fault reaction time of the safety system
- the SFF value (**S**afe **F**ailure **F**raction)
- the HFT architecture (**H**ardware **F**ault **T**olerance)

3.1.3 Safe Failure Fraction

The safe failure fraction describes the ratio of all safe failures and dangerous detected failures to the total failure rate.

$$SFF = (\lambda_s + \lambda_{dd}) / (\lambda_s + \lambda_{dd} + \lambda_{du})$$

A safe failure fraction as defined in IEC/EN 61508 is only relevant for elements or (sub)systems in a complete safety loop. The device under consideration is always part of a safety loop but is not regarded as a complete element or subsystem.

For calculating the SIL of a safety loop it is necessary to evaluate the safe failure fraction of elements, subsystems and the complete system, but not of a single device.

Nevertheless the SFF of the device is given in this document for reference.

3.2

Assumptions

The following assumptions have been made during the FMEDA:

- Failure rate based on the Siemens standard SN29500.
- Failure rates are constant, wear is not considered.
- External power supply failure rates are not included.
- The safety-related device is considered to be of type **A** device with a hardware fault tolerance of **0**.
- The device will be used under average industrial ambient conditions, which are comparable with the classification "stationary mounted" in MIL-HDBK-217F. Alternatively, the following ambient conditions are assumed:
 - IEC/EN 60654-1 Class C (sheltered location) with temperature limits in the range of the manufacturer's specifications and an average temperature of 40 °C over a long period. The humidity level is within manufacturer's rating. For a higher average temperature of 60 °C, the failure rates must be multiplied by a factor of 2.5 based on experience. A similar factor must be used if frequent temperature fluctuations are expected.
- The HART function is only used for configuration, calibration and diagnostics, not during operation.
- The application program in the programmable logic controller (PLC) is configured to detect underrange and overrange failures.
- Since the two outputs of the device use common components, these outputs must not be used in the same safety function.

SIL 2 Application

- The device shall claim less than 10 % of the total failure budget for a SIL 2 safety loop.
- For a SIL 2 application operating in low demand mode the total PFD_{avg} value of the SIF (**S**afety **I**nstrumented **F**unction) should be smaller than 10^{-2} , hence the maximum allowable PFD_{avg} value would then be 10^{-3} .
- For a SIL 2 application operating in high demand mode the total PFH value of the SIF should be smaller than 10^{-6} per hour, hence the maximum allowable PFH value would then be 10^{-7} per hour.
- Since the safety loop has a hardware fault tolerance of **0** and it is a type **A** device, the SFF must be > 60 % according to table 2 of IEC/EN 61508-2 for a SIL 2 (sub) system.

SIL 3 Application

SIL 3 can be reached if the two outputs of the device are connected to the same control interface and evaluated if the deviation remains below 2 %.

- The device shall claim less than 10 % of the total failure rate for a SIL 3 safety loop.
- For a SIL 3 application operating in low demand mode the total PFD_{avg} value of the SIF (Safety Instrumented Function) should be smaller than 10^{-3} , hence the maximum allowable PFD_{avg} value would then be 10^{-4} .
- For a SIL 3 application operating in high demand mode the total PFH value of the SIF should be smaller than 10^{-7} per hour, hence the maximum allowable PFH value would then be 10^{-8} per hour.
- Since the safety loop has a hardware fault tolerance of **0** and it is a type **A** device, the SFF must be > 90 % according to table 2 of IEC/EN 61508-2 for a SIL 3 (sub) system.

3.3 Safety Function and Safe State

Safety Function

The device transfers analog signals from the input to the output with a deviation of less than 2 %.

Device	Input signals	Output signals
KFD2-STC5-1, KFD2-STC5-Ex1, KFD2-STC5-Ex1.H KFD2-STC5-1.2O, KFD2-STC5-Ex1.2O, KFD2-STC5-Ex1.2O.H, HiD2022, HiD2022SK, KFD2-STC5-2, KFD2-STC5-Ex2	0/4 mA to 20 mA	0/4 mA to 20 mA
KFD2-STV5-1-1, KFD2-STV5-Ex1-1, KFD2-STV5-Ex1.2O-1, KFD2-STV5-2-1, KFD2-STV5-Ex2-1	0/4 mA to 20 mA	0/1 V to 5 V
KFD2-STV5-Ex1-2, KFD2-STV5-Ex1.2O-2, KFD2-STV5-Ex2-2	0/4 mA to 20 mA	0/2 V to 10 V

Table 3.1

Safe State

Ensure that the emergency shutdown (ESD) reacts adequately when the outputs are

- < 4 mA or > 20 mA,
- < 1 V or > 5 V,
- < 2 V or > 10 V.

Failures that introduce the safe state show that either the device or the attached periphery is defective as a live zero signal is expected. Due to this, these failures are counted as dangerous detected failures for the system.

Reaction Time

The reaction time for all safety functions is < 100 ms.

Functional Safety Connection Configuration for KFD2-*-(Ex)1.20* Devices**




Figure 3.1 SIL 2 application




Figure 3.2 SIL 3 application



Note!

See corresponding datasheets for further information.

3.4 Characteristic Safety Values

**KFD2-STC5-1, KFD2-STC5-Ex1, KFD2-STC5-Ex1.H, KFD2-STV5-1-1,
KFD2-STV5-Ex1-1, KFD2-STV5-Ex1-2
HiD2022, HiD2022SK, KFD2-STC5-2, KFD2-STC5-Ex2, KFD2-STV5-2-1,
KFD2-STV5-Ex2-1, KFD2-STV5-Ex2-2**

Parameters acc. to IEC 61508	Characteristic values
Assessment type and documentation	FMEDA report
Device type	A
Operating mode	Low Demand Mode or High Demand Mode
Safety function	Transfer of analog signals
HFT	0
SIL (SC)	2
λ_s^1	0 FIT
λ_{dd}^2	169 FIT
λ_{du}	67 FIT
$\lambda_{not\ part}$	70 FIT
λ_{total} (safety function)	236 FIT
λ_{total}	653 FIT
SFF	72 %
PTC	100 %
MTBF ³	175 years
PFH	6.72×10^{-8} 1/h
PFD _{avg} for $T_1 = 1$ year	2.94×10^{-4}
PFD _{avg} for $T_1 = 2$ years	5.88×10^{-4}
PFD _{avg} for $T_1 = 5$ years	1.47×10^{-3}
Reaction time ⁴	< 100 ms

Table 3.2

- 1 "No effect failures" are not influencing the safety function and are therefore not included in SFF and in the failure rates of the safety function.
- 2 "Fail high" and "Fail low" failures are considered as dangerous detected failures λ_{dd} .
- 3 acc. to SN29500. This value includes failures which are not part of the safety function/MTTR = 24 h. The value is valid for one safety loop only.
- 4 Time between fault detection and fault reaction

**KFD2-STC5-1.20, KFD2-STC5-Ex1.20, KFD2-STC5-Ex1.20.H,
KFD2-STV5-Ex1.20-1, KFD2-STV5-Ex1.20-2**

Parameters acc. to IEC 61508	Characteristic values	
Assessment type and documentation	FMEDA report	
Device type	A	
Operating mode	Low Demand Mode or High Demand Mode	
Safety function	Transfer of analog signals	
HFT	0	
SIL (SC)	2	3
Input and output function	1 output used in safety function	2 outputs used in safety function
λ_s^1	0 FIT	0 FIT
λ_{dd}^2	177 FIT	328 FIT
λ_{du}^3	57 FIT	9.3 FIT
$\lambda_{not\ part}$	72 FIT	114 FIT
$\lambda_{total\ (safety\ function)}$	234 FIT	337 FIT
λ_{total}	660 FIT	954 FIT
SFF	80 %	97.3 %
PTC	100 %	100 %
MTBF ⁴	173 years	119 years
PFH ³	5.67×10^{-8} 1/h	9.27×10^{-9} 1/h
PFD _{avg} for T ₁ = 1 year	2.48×10^{-4}	4.06×10^{-5}
PFD _{avg} for T ₁ = 2 years	4.97×10^{-4}	8.12×10^{-5}
PFD _{avg} for T ₁ = 5 years	1.24×10^{-3}	2.03×10^{-4}
Reaction time ⁵	< 100 ms	

Table 3.3

- ¹ "No effect failures" are not influencing the safety function and are therefore not included in SFF and in the failure rates of the safety function.
- ² "Fail high" and "Fail low" failures are considered as dangerous detected failures λ_{dd} .
- ³ The safety characteristic values were calculated considering a common cause factor β of 5 % for the safety relevant output part.
For the application with 2 outputs in the safety function, the ESD system needs to detect if the outputs differ by more than 2 %.
- ⁴ acc. to SN29500. This value includes failures which are not part of the safety function/MTTR = 24 h. The value is valid for one safety loop only.
- ⁵ Time between fault detection and fault reaction

The characteristic safety values like PFD, SFF, HFT and T₁ are taken from the SIL report/FMEDA report. Observe that PFD and T₁ are related to each other.

The function of the devices has to be checked within the proof test interval (T₁).

3.5 Useful Life Time

Although a constant failure rate is assumed by the probabilistic estimation this only applies provided that the useful lifetime of components is not exceeded. Beyond this useful lifetime, the result of the probabilistic estimation is meaningless as the probability of failure significantly increases with time. The useful lifetime is highly dependent on the component itself and its operating conditions – temperature in particular. For example, the electrolytic capacitors can be very sensitive to the operating temperature.

This assumption of a constant failure rate is based on the bathtub curve, which shows the typical behavior for electronic components.

Therefore it is obvious that failure calculation is only valid for components that have this constant domain and that the validity of the calculation is limited to the useful lifetime of each component.

It is assumed that early failures are detected to a huge percentage during the installation and therefore the assumption of a constant failure rate during the useful lifetime is valid.

However, according to IEC/EN 61508-2, a useful lifetime, based on general experience, should be assumed. Experience has shown that the useful lifetime often lies within a range period of about 8 to 12 years.

As noted in DIN EN 61508-2:2011 note N3, appropriate measures taken by the manufacturer and plant operator can extend the useful lifetime.

Our experience has shown that the useful lifetime of a Pepperl+Fuchs product can be higher if the ambient conditions support a long life time, for example if the ambient temperature is significantly below 60 °C.

Please note that the useful lifetime refers to the (constant) failure rate of the device. The effective life time can be higher.

4 Mounting and Installation



Installing the device

1. Observe the safety instructions in the instruction manual.
2. Observe the information in the manual.
3. Observe the requirements for the safety loop.
4. Connect the device only to devices that are suitable for this safety application.
5. Check the safety function to ensure the expected output behavior.

4.1 Configuration

A configuration of the device is not necessary and not possible.

5 Operation



Danger!

Danger to life from missing safety function

If the safety loop is put out of service, the safety function is no longer guaranteed.

- Do not deactivate the device.
- Do not bypass the safety function.
- Do not repair, modify, or manipulate the device.



Operating the device

1. Observe the safety instruction in the instruction manual.
2. Observe the information in the manual.
3. Use the device only with devices that are suitable for this safety application.
4. Correct any occurring safe failures within 24 hours. Take measures to maintain the safety function while the device is being repaired.

5.1 Proof Test Procedure

According to IEC/EN 61508-2 a recurring proof test shall be undertaken to reveal potential dangerous failures that are not detected otherwise.

Check the function of the subsystem at periodic intervals depending on the applied PFD_{avg} in accordance with the characteristic safety values. See chapter 5.1.

It is under the responsibility of the plant operator to define the type of proof test and the interval time period.

Equipment required:

- Digital multimeter with an accuracy better than 0.1 %
Use for the proof test of the intrinsic safety side of the device a special digital multimeter for intrinsically safe circuits.
If intrinsically safe circuits are operated with non-intrinsically safe circuits, they must no longer be used as intrinsically safe circuits.
- Power supply set to nominal voltage of 24 V DC
- Process calibrator with current source and current sink function with an accuracy better than 20 μ A



Proof Test Procedure

1. Put out of service the entire safety loop. Protect the application by means of other measures.
2. Prepare a test set-up, see figures below.
3. Test the devices. Verify the current values as given in table below.
4. Set back the device to the original settings for the application after the test.

Proof Test for 1- and 2-Channel Devices

Step No.	Input value (mA)	Output value		
		Current source/current sink (mA) for KFD2-STC5-(Ex)*-*(.H)	Voltage source (V) for KFD2-STV5-(Ex)*-1	Voltage source (V) for KFD2-STV5-(Ex)*-2
1	20.0	20.0 ± 0.4	5.0 ± 0.1	10.0 ± 0.2
2	12.0	12.0 ± 0.4	3.0 ± 0.1	6.0 ± 0.2
3	4.0	4.0 ± 0.4	1.0 ± 0.1	2.0 ± 0.2
4	23.0	23.0 ± 0.4	5.75 ± 0.1	11.5 ± 0.2
5	0	< 0.2	< 0.1	< 0.1

Table 5.1




Figure 5.1 Proof test set-up for KFD2-STC5-(Ex)*-*(.H)

Usage in Zone 0, 1, 2/Div. 1, 2 only for KFD2-STC5-Ex1, KFD2-STC5-Ex1.H, and KFD2-STC5-Ex2

The KFD2-STC5-1, KFD2-STC5-Ex1, and KFD2-STC5-Ex1.H devices have no second channel.




Figure 5.2 Proof test set-up for KFD2-STV5-(Ex)*-1 and KFD2-STV5-(Ex)*-2

Usage in Zone 0, 1, 2/Div. 1, 2 only for KFD2-STV5-Ex1-1, KFD2-STV5-Ex1-2, KFD2-STV5-Ex2-1, and KFD2-STV5-Ex2-2

The KFD2-STV5-1-1, KFD2-STV5-Ex1-1, and KFD2-STV5-Ex1-2 devices have no second channel.

Proof Test for Devices with Splitter Function (1.2O)

Step No.	Input value (mA)	Output value		
		Current source/current sink (mA) for KFD2-STC5-(Ex) 1.2O(.H)	Voltage source (V) for KFD2-STV5-Ex1.2O-1	Voltage source (V) for KFD2-STV5-Ex1.2O-2
1	20.0	20.0 ± 0.4	5.0 ± 0.1	10.0 ± 0.2
2	12.0	12.0 ± 0.4	3.0 ± 0.1	6.0 ± 0.2
3	4.0	4.0 ± 0.4	1.0 ± 0.1	2.0 ± 0.2
4	23.0	23.0 ± 0.4	5.75 ± 0.1	11.5 ± 0.2
5	0	< 0.2	< 0.1	< 0.1

Table 5.2




Figure 5.3 Proof test set-up for KFD2-STC5-(Ex) 1.2O(.H)

Usage in Zone 0, 1, 2/Div. 1, 2 only for KFD2-STC5-Ex1.2O and KFD2-STC5-Ex1.2O.H




Figure 5.4 Proof test set-up for KFD2-STV5-Ex1.2O-1 and KFD2-STV5-Ex1.2O-2

Proof Test for 2-Channel H-System Devices

Step No.	Input value (mA)	Output value
		Current source/current sink (mA) for HiD2022(SK)
1	20.0	20.0 ± 0.4
2	12.0	12.0 ± 0.4
3	4.0	4.0 ± 0.4
4	23.0	23.0 ± 0.4
5	0	< 0.2

Table 5.3




Figure 5.5 Proof test set-up for HiD2022(SK)



Tip

The easiest way to test HiD devices by using a stand-alone HiDTB**-SCT-***-***-** termination board. In this test, it is not necessary to disconnect the wiring of the existing application. Faults in a subsequent wiring can be avoided.

6 Maintenance and Repair



Danger!

Danger to life from missing safety function

If the safety loop is put out of service, the safety function is no longer guaranteed.

- Do not deactivate the device.
- Do not bypass the safety function.
- Do not repair, modify, or manipulate the device.



Maintaining, Repairing or Replacing the Device

In case of maintenance, repair or replacement of the device, proceed as follows:

1. Implement appropriate maintenance procedures for regular maintenance of the safety loop.
2. Ensure the proper function of the safety loop, while the device is maintained, repaired or replaced.
If the safety loop does not work without the device, shut down the application.
Do not restart the application without taking proper precautions.
Secure the application against accidental restart.
3. Do not repair a defective device. A defective device must only be repaired by the manufacturer.
4. Replace a defective device only by a device of the same type.

7

List of Abbreviations

ESD	Emergency Shutdown
FIT	Failure In Time in 10^{-9} 1/h
FMEDA	Failure Mode, Effects, and Diagnostics Analysis
λ_s	Probability of safe failure
λ_{dd}	Probability of dangerous detected failure
λ_{du}	Probability of dangerous undetected failure
$\lambda_{no\ effect}$	Probability of failures of components in the safety loop that have no effect on the safety function. The no effect failure is not used for calculation of SFF.
$\lambda_{not\ part}$	Probability of failure of components that are not in the safety loop
$\lambda_{total\ (safety\ function)}$	Safety function
HFT	Hardware Fault Tolerance
MTBF	Mean Time Between Failures
MTTR	Mean Time To Restoration
PCS	Process Control System
PFDA_{avg}	Average Probability of dangerous Failure on Demand
PFH	Average frequency of dangerous failure
PTC	Proof Test Coverage
SFF	Safe Failure Fraction
SIF	Safety Instrumented Function
SIL	Safety Integrity Level
SIL (SC)	Safety Integrity Level (Systematic Capability)
SIS	Safety Instrumented System
T₁	Proof Test Interval







PROCESS AUTOMATION – PROTECTING YOUR PROCESS



Worldwide Headquarters

Pepperl+Fuchs GmbH
68307 Mannheim · Germany
Tel. +49 621 776-0
E-mail: info@de.pepperl-fuchs.com

For the Pepperl+Fuchs representative
closest to you check www.pepperl-fuchs.com/contact

www.pepperl-fuchs.com

Subject to modifications
Copyright PEPPERL+FUCHS • Printed in Germany

 **PEPPERL+FUCHS**
PROTECTING YOUR PROCESS



SCATTERGOOD & JOHNSON LTD

ELECTRICAL ENGINEERING & FLUID CONTROL DISTRIBUTORS

Est.1899


At Scattergood & Johnson Ltd, we pride ourselves on being a technical distributor to specialist industries.

Working with a range of quality product suppliers across a number of specialist markets, we are not your average 'box shifter' - we are your technical and supply chain partner.

We fully support every product we sell - for free! Our internal team and external sales engineers can answer any product or application question, no matter the complexity.

Backing up this technical ability is a range of 50,000+ products available from stock for nationwide next day delivery (same day if required!), or you can collect what you need from any of our trade counters around the UK.

Select your specialist interest below to learn more about how we can help.



Online, In Branch and On the Road - Scattergood & Johnson Ltd, there when you need us.

www.scatts.co.uk