

Certificate Number
Baseefa03ATEX0141
Issue 3



Issued 7 July 2015
Page 1 of 4

1 EC - TYPE EXAMINATION CERTIFICATE

2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

3 EC - Type Examination Certificate Number: **Baseefa03ATEX0141 – Issue 3**

4 Equipment or Protective System: **Transformer Isolated Loop Powered Current Separator Type KFD0-CS-Ex*.52**

5 Manufacturer: **Pepperl + Fuchs GmbH**

6 Address: **Lilienthalstrasse 200, 68307 Mannheim, Germany**

7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Baseefa, Notified Body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No's. See Certificate History

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2012+A11:2013 EN 60079-11:2012

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include the following :

⊕ II (1) G [Ex ia Ga] IIC (-20°C ≤ Ta ≤ +60°C)

⊕ II (1) D [Ex ia Da] IIC (-20°C ≤ Ta ≤ +60°C)

⊕ I (M1) [Ex ia Ma] I (-20°C ≤ Ta ≤ +60°C)

Baseefa Customer Reference No. **0808**

Project File No. **15/0067**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.baseefa.com/terms-and-conditions.asp>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
 Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail info@baseefa.com web site www.baseefa.com

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

R S SINCLAIR

GENERAL MANAGER

On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa03ATEX0141 – Issue 3

15 Description of Equipment or Protective System

A Transformer Isolated, Loop Powered, Current Separator Type KFD0-CS-Ex*.52 is designed to restrict the transfer of energy from unspecified Non Hazardous Area Apparatus to Hazardous Area Apparatus without the need for a high integrity earth. The unit is intended to provide a signal return path from the hazardous area and both a dual and a single channel version is available. The "*" in the type number is replaced by a "2" for the dual channel version and a "1" for the single channel version.

The apparatus is designed for a rated input voltage not exceeding 40V d.c. but the creepage and clearance distances between the non-hazardous area and the hazardous area circuitry are acceptable for a peak voltage of 375 volts, (253V volts r.m.s.)

The apparatus comprises a maximum of two channels, and each channel comprises a transformer and electronic components mounted on a printed circuit board and housed within a plastic enclosure which is fitted with terminals for the connection of external equipment.

Input/Output Parameters

Non-Hazardous Area Terminals 8 to 12

$$U_m = 253V$$

The apparatus is designed to operate from a d.c. supply of up to 40V on the above terminals.

Hazardous Area Terminals 1 w.r.t. 2 (Channel 1) and 4 w.r.t. 5 (Channel 2)

Each channel may be considered as a separate intrinsically safe circuit.

$$\begin{array}{ll} U_o = 25.2V & U_i = 25.2V \\ I_o = 0 & I_i = 121mA \\ P_o = 0 & P_i = 762mW \\ C_i = 0 & \\ L_i = 0 & \end{array}$$

The hazardous area terminals of each channel of this equipment must be treated as a 25.2 Volt source. The 25.2 Volts is considered as being the theoretical maximum to which a capacitive load across the hazardous area terminals could become charged through the series blocking diodes. This voltage does not contribute to the short circuit sparking risk across the hazardous area terminals but only to the calculation of the load capacitance.

The Capacitance and either the Inductance or the Inductance to Resistance (L/R) ratio of the cables connected to the Hazardous Area Connectors should not exceed the following values:

GROUP	CAPACITANCE (μ F)	INDUCTANCE (mH)	OR L/R RATIO (μ H/ohm)
IIC	0.107	1000	947
IIB	0.82	1000	947
IIA	2.9	1000	947
I	4.15	1000	947

The above parameters apply when one of the two conditions below is given:

- the total L_i of the external circuit (excluding the cable) is < 1% of the L_o value or
- the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.

Certificate Number
Baseefa03ATEX0141
Issue 3



Issued 7 July 2015
Page 3 of 4

The above parameters are reduced to 50% when both of the two conditions below are given:

- the total L_i of the external circuit (excluding the cable) $\geq 1\%$ of the L_o value and
- the total C_i of the external circuit (excluding the cable) $\geq 1\%$ of the C_o value.

Note: the reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu\text{F}$ for Groups I, IIA & IIB and 600nF for Group IIC.

16 Report Number

GB/BAS/ExTR15.0021/00

17 Specific Conditions of Use

None.

18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 Drawings and Documents

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
266-0039BS-A	1 of 1	A	2014-Oct-15	Summary
266-0039BS-10A	1 – 3	A	2014-Oct-15	Type Label
266-010BS-04E	1 – 15	E	2014-Mar-27	Mechanical Parts

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
266-0039BS-00	1 to 10	-	2008-Sep-30	Description
266-0039BS-01	1 & 2	-	2008-Mar-20	Schematic
266-0039BS-02	1	-	2008-Sep-26	I.S. Relevant Components
266-0039BS-03	1	-	2008-Sep-29	Component Layout
266-0039BS-05	1 & 2	-	2008-Sep-29	PCB Layout
266-0039BS-06	1 to 3	-	2008-Mar-20	Transformer Details
266-0039BS-07	1 & 2	-	2008-Sep-29	PCB Lacquering Details

These drawings are common to, and held with, IECEx BAS 08.0059.






20 Certificate History

Certificate No.	Date	Comments
Baseefa03ATEX0141	10 April 2003	The release of the prime certificate. The associated test and assessment is documented in Test Report No. 03(C)0171.
Baseefa03ATEX0141/1	23 March 2004	To permit the replacement of a diode type with an equivalent type. Project File No. 04/0192
Baseefa03ATEX0141/2	27 February 2008	To permit minor electrical changes, a change of manufacturer address and to confirm that the equipment covered by this certificate has been reviewed against the requirements of EN 60079-0:2006 and EN 60079-11:2007 in respect of the differences from EN 50014:1997 + A1 & A2 and EN 50020:2002 and that none of these differences affect this equipment. The equipment is also considered suitable for Group I applications and has additionally been assessed against the relevant requirements of EN 61241-11:2006 and the following additional marking may be applied:

Certificate Number
Baseefa03ATEX0141
Issue 3



Issued 7 July 2015
Page 4 of 4

Certificate No.	Date	Comments
		<p>  I (M1) [Ex ia] I  II (1)D [Ex iaD] Test Report No. GB/BAS/ExTR08.0116/00. Project File No. 08/0267. </p>
<p>Baseefa03ATEX0141 Issue 3</p>	<p>7 July 2015</p>	<p>This issue incorporates previously issued primary and supplementary certificates into one certificate, permits changes to the transformer and confirms that the equipment covered by this certificate has been reviewed against the requirements of EN 60079-0:2012+A11:2013 and EN 60079-11:2012 in respect of the differences from EN 60079-0:2006 and EN 60079-11:2007 and that none of these differences, with the exception of marking, affect this equipment. The equipment is now marked:</p> <p>  II (1)G [Ex ia Ga] IIC  II (1)D [Ex ia Da] IIIC  I (M1) [Ex ia Ma] I </p> <p>Test Report No. GB/BAS/ExTR15.0021/00. Project File No. 15/0067.</p>
<p>For drawings applicable to each issue, see original of that issue.</p>		



SCATTERGOOD & JOHNSON LTD

ELECTRICAL ENGINEERING & FLUID CONTROL DISTRIBUTORS

Est.1899

At Scattergood & Johnson Ltd, we pride ourselves on being a technical distributor to specialist industries.

Working with a range of quality product suppliers across a number of specialist markets, we are not your average 'box shifter' - we are your technical and supply chain partner.

We fully support every product we sell - for free! Our internal team and external sales engineers can answer any product or application question, no matter the complexity.

Backing up this technical ability is a range of 50,000+ products available from stock for nationwide next day delivery (same day if required!), or you can collect what you need from any of our trade counters around the UK.

Select your specialist interest below to learn more about how we can help.



Online, In Branch and On the Road - Scattergood & Johnson Ltd, there when you need us.

www.scatts.co.uk