



HUBBELL ELECTRICAL PRODUCTS
Division of HUBBELL INCORPORATED (Delaware)
 3940 Martin Luther King Drive
 St. Louis, Missouri 63113 USA

KILLARK®**INSTALLATION, OPERATION & MAINTENANCE DATA SHEET****KDB-1 DRAIN and BREATHER****FOR CLASS I, GROUPS C & D, CLASS II, GROUPS E, F, & G, & CLASS III
HAZARDOUS LOCATIONS**

**CAUTION: IN CASE OF INSTALLING OR REPLACING DRAIN IN AN OPERATING ELECTRICAL ENCLOSURE,
TURN OFF MAIN POWER BEFORE PROCEEDING WITH THE TASK.**

Select a suitable, flat area on the top (for a breather) or bottom (for a drain) of an enclosure, and drill and tap a 1/2"-14 NPT hole for each KDB-1. The tapped hole must have 5 full threads engagement for Class I, and 3-1/2 threads for Class II & III locations. Note: a KDB-1 fitting can also be installed in an existing 1/2"-14 NPT conduit hub. When selecting a location for a drain, the opening should be as close as possible to the lowest point on the enclosures interior, to ensure maximum drainage. Apply a small amount of Killark "LUBG" lubricant to the KDB threads and install in threaded opening. Tighten snugly.

These fittings require no maintenance other than a periodic inspection for clogs or damage. If the fitting is damaged or broken, it should be replaced entirely.

**REMEMBER TO SAVE ONE OF THESE SHEETS FOR
MAINTENANCE PERSONNEL.**

P/N 00905787 FORM NO. K0817 R0511 ECO-8-020-11



HUBBELL ELECTRICAL PRODUCTS
A Division of HUBBELL INCORPORATED (Delaware)
 3940 Martin Luther King Drive
 St. Louis, Missouri 63113 USA

KILLARK®**INSTALLATION, OPERATION & MAINTENANCE DATA SHEET****KDB-1 DRAIN and BREATHER****FOR CLASS I, GROUPS C & D, CLASS II, GROUPS E, F, & G, & CLASS III
HAZARDOUS LOCATIONS**

**CAUTION: IN CASE OF INSTALLING OR REPLACING DRAIN IN AN OPERATING ELECTRICAL ENCLOSURE,
TURN OFF MAIN POWER BEFORE PROCEEDING WITH THE TASK.**

Select a suitable, flat area on the top (for a breather) or bottom (for a drain) of an enclosure, and drill and tap a 1/2"-14 NPT hole for each KDB-1. The tapped hole must have 5 full threads engagement for Class I, and 3-1/2 threads for Class II & III locations. Note: a KDB-1 fitting can also be installed in an existing 1/2"-14 NPT conduit hub. When selecting a location for a drain, the opening should be as close as possible to the lowest point on the enclosures interior, to ensure maximum drainage. Apply a small amount of Killark "LUBG" lubricant to the KDB threads and install in threaded opening. Tighten snugly.

These fittings require no maintenance other than a periodic inspection for clogs or damage. If the fitting is damaged or broken, it should be replaced entirely.

**REMEMBER TO SAVE ONE OF THESE SHEETS FOR
MAINTENANCE PERSONNEL.**

P/N 00905787 FORM NO. K0817 R0511 ECO-8-020-11



HUBBELL ELECTRICAL PRODUCTS
Division of HUBBELL INCORPORATED (Delaware)
 3940 Martin Luther King Drive
 St. Louis, Missouri 63113 USA

KILLARK®**INSTALLATION, OPERATION & MAINTENANCE DATA SHEET****KDB-1 DRAIN and BREATHER****FOR CLASS I, GROUPS C & D, CLASS II, GROUPS E, F, & G, & CLASS III
HAZARDOUS LOCATIONS**

**CAUTION: IN CASE OF INSTALLING OR REPLACING DRAIN IN AN OPERATING ELECTRICAL ENCLOSURE,
TURN OFF MAIN POWER BEFORE PROCEEDING WITH THE TASK.**

Select a suitable, flat area on the top (for a breather) or bottom (for a drain) of an enclosure, and drill and tap a 1/2"-14 NPT hole for each KDB-1. The tapped hole must have 5 full threads engagement for Class I, and 3-1/2 threads for Class II & III locations. Note: a KDB-1 fitting can also be installed in an existing 1/2"-14 NPT conduit hub. When selecting a location for a drain, the opening should be as close as possible to the lowest point on the enclosures interior, to ensure maximum drainage. Apply a small amount of Killark "LUBG" lubricant to the KDB threads and install in threaded opening. Tighten snugly.

These fittings require no maintenance other than a periodic inspection for clogs or damage. If the fitting is damaged or broken, it should be replaced entirely.

**REMEMBER TO SAVE ONE OF THESE SHEETS FOR
MAINTENANCE PERSONNEL.**

P/N 00905787 FORM NO. K0817 R0511 ECO-8-020-11



HUBBELL ELECTRICAL PRODUCTS
Division of HUBBELL INCORPORATED (Delaware)
 3940 Martin Luther King Drive
 St. Louis, Missouri 63113 USA

KILLARK®**INSTALLATION, OPERATION & MAINTENANCE DATA SHEET****KDB-1 DRAIN and BREATHER****FOR CLASS I, GROUPS C & D, CLASS II, GROUPS E, F, & G, & CLASS III
HAZARDOUS LOCATIONS**

**CAUTION: IN CASE OF INSTALLING OR REPLACING DRAIN IN AN OPERATING ELECTRICAL ENCLOSURE,
TURN OFF MAIN POWER BEFORE PROCEEDING WITH THE TASK.**

Select a suitable, flat area on the top (for a breather) or bottom (for a drain) of an enclosure, and drill and tap a 1/2"-14 NPT hole for each KDB-1. The tapped hole must have 5 full threads engagement for Class I, and 3-1/2 threads for Class II & III locations. Note: a KDB-1 fitting can also be installed in an existing 1/2"-14 NPT conduit hub. When selecting a location for a drain, the opening should be as close as possible to the lowest point on the enclosures interior, to ensure maximum drainage. Apply a small amount of Killark "LUBG" lubricant to the KDB threads and install in threaded opening. Tighten snugly.

These fittings require no maintenance other than a periodic inspection for clogs or damage. If the fitting is damaged or broken, it should be replaced entirely.

**REMEMBER TO SAVE ONE OF THESE SHEETS FOR
MAINTENANCE PERSONNEL.**

P/N 00905787 FORM NO. K0817 R0511 ECO-8-020-11



SCATTERGOOD & JOHNSON LTD

ELECTRICAL ENGINEERING & FLUID CONTROL DISTRIBUTORS

At Scattergood & Johnson Ltd, we pride ourselves on being a technical distributor to specialist industries.

Working with a range of quality product suppliers across a number of specialist markets, we are not your average 'box shifter' - we are your technical and supply chain partner.

We fully support every product we sell - for free! Our internal team and external sales engineers can answer any product or application question, no matter the complexity.

Backing up this technical ability is a range of 50,000+ products available from stock for nationwide next day delivery (same day if required!), or you can collect what you need from any of our trade counters around the UK.

Select your specialist interest below to learn more about how we can help.



Online, In Branch and On the Road - Scattergood & Johnson Ltd, there when you need us.

www.scatts.co.uk