



EU Type Examination Certificate CML 20ATEX2254X Issue 0

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **BA320x CPU Module**
- 3 Manufacturer **BEKA associates Ltd.**
- 4 Address **Old Charlton Road, Hitchin, Herts.
SG5 2DA, UK**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V., Chamber of Commerce No 6738671, Koopvaardijweg 32, 4906CV Oosterhout, The Netherlands, Notified Body Number 2776, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:
EN IEC 60079-0:2018 EN 60079-11:2012
- 10 The equipment shall be marked with the following:



II 1 G D

Ex ia IIC T4 Ga

Ex ia IIIC T120°C Da

-40°C ≤ Ta ≤ +65°C

A Snowden

A Snowden
Assistant Certification Manager

This certificate shall only be copied
in its entirety and without change

www.CMLEx.com



CML 20ATEX2254X
Issue 0

11 Description

The BA320x CPU Module is an intrinsically safe module intended for use with the Pageant system. The module comprises circuit boards mounted within a non-metallic enclosure with a single card edge connector for plugging into separately certified equipment (e.g. the Pageant Display unit).

The equipment also carries a terminal block for connection of the external supply and a programming connector for use in the safe area only.

Depending on the model type, the equipment may contain a communications module with connector for connection to separately certified intrinsically safe equipment.

The following model types are available:

Model number	Description
BA3201	CPU only, no communications option fitted
BA3202	CPU unit with Modbus RTU communications
BA3203	CPU unit with Profibus DP communications

Intrinsic safety is achieved by limiting energy storage and discharge, and by connecting to other equipment via intrinsically safe interface devices.

The equipment has the following intrinsically safe parameters for each connector:

Barrier Power in TB1 Terminals 1-2	Barrier Power out PL1 Terminals 39, 40			3V3_CPU supply PL1 Terminals 29, 31	Data Buses PL1 Terminals 1- 14, 17-22, 24, 26, 28, 30, 32	Comms Port SK100 Terminals 1- 9
U _i = 12.4V				U _i = 4.1V	U _i = 4.1V	U _i = 4.2V
I _i = 2.68A				I _i = 2.30A		
P _i = 5.44W				P _i = 1.09W		
	U _o = 12.4V				U _o = 4.1V	U _o = 3.8V
	I _o = 2.68A				I _o = 203mA	I _o = 132mA
	P _o = 5.44W				P _o = 208mW	P _o = 126mW
C _i = 0	C _i = 0			C _i = 498μF	C _i = 0	C _i = 0
L _i = 0	L _i = 4μH			L _i = 0	L _i = 0	L _i = 0
	SEE NOTE 1	Co =	Lo =			
	IIA	30μF	35.6μH			
	IIB	7.9μF	15.8μH			
	IIC	1.24μF	0.95μH			
	III	7.9μF	15.8μH			



CML 20ATEX2254X
Issue 0

NOTE 1 - The above load parameters apply when one of the two conditions below is met:

- the total Li of the external circuit (excluding the cable) is < 1% of the Lo value or
- the total Ci of the external circuit (excluding the cable) is < 1% of the Co value.

If neither of the above conditions are met, the load parameters are both reduced by 50%. Additionally, the reduced capacitance of the external circuit (including cable) shall not be greater than 1µF for Groups IIA, IIB, and III, and 600nF for Group IIC.

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	25 Jun 2021	R13616A/00	Issue of prime certificate

Note: Drawings that describe the equipment or component are listed in the Annex.

13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
- ii. The manufacturer shall ensure that sufficient documentation is provided with the equipment pertaining to the architecture and design of the BEKA Pageant System, to permit the user to make the necessary intrinsically safe system calculations and documentation.

14 Specific Conditions of Use (Special Conditions)

The following conditions relate to safe installation and/or use of the equipment.

- i. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore, the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.
- ii. In installations requiring EPL Da, Db, or Dc, the equipment shall be mounted within an enclosure which provides a minimum degree of protection of IP5X and which meets the requirements of EN 60079-0 Clause 8.4 (material composition requirements for metallic enclosures for Group III) and/or EN 60079-0 Clause 7.4.3 (Avoidance of a build-up of electrostatic charge for Group III) as appropriate.

All cable entries into the equipment shall be made via cable glands which provide a minimum degree of protection of IP5X.
- iii. The equipment shall only be connected to programming equipment via SK3 when in the safe area and shall only be connected via the galvanically isolating interface unit provided by the manufacturer.
- iv. This equipment shall only be used as part of a BEKA Pageant System.

Certificate Annex

Certificate Number CML 20ATEX2254X
Equipment BA320x CPU Module
Manufacturer BEKA associates Ltd.



The following documents describe the equipment or component defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved date	Title
CI3201-01	1 to 22	1	25 Jun 2021	ATEX & IECEx Certification Information for BEKA BA320x CPU Module



**SCATTERGOOD
& JOHNSON LTD**
ELECTRICAL ENGINEERING & FLUID CONTROL DISTRIBUTORS

Est.1899

At Scattergood & Johnson Ltd, we pride ourselves on being a technical distributor to specialist industries.

Working with a range of quality product manufacturers across a number of specialist markets, we are not your average 'box shifter' - we are your technical and supply chain partner.

We fully support every product we sell - for free! Our internal team and external sales engineers can answer any product or application question, no matter the complexity.

Backing up this technical ability is a range of 50,000+ products available from stock for nationwide next day delivery (same day if required!), or you can collect what you need from any of our trade counters around the UK.

Select your specialist interest below to learn more about how we can help.



Online, In Branch and On the Road - Scattergood & Johnson Ltd, there when you need us.

www.scatts.co.uk