

Type Examination Certificate CML 21UKEX4106 Issue 3

United Kingdom Conformity Assessment


- 1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended)
- 2 Equipment **Spartan SPZ Floodlight/Bulkhead Luminaire**
- 3 Manufacturer **Raytec Ltd**
- 4 Address **Unit 15 Wansbeck Business Park,
Rotary Parkway,
Ashington, Northumberland,
NE63 8QW, United Kingdom**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, United Kingdom, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to specific conditions of use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018	EN 60079-1:2014	EN IEC 60079-7:2015+A1:2018
EN 60079-18:2015+A1:2017	EN 60079-31:2014	


- 10 The equipment shall be marked with the following:

FL** (No Sockets)



Ex ec mc IIC T4 Gc
Ex tc IIIC T82°C Dc
Ta = -50 °C to +55 °C
IP66 IP67


FL** Emergency



Ex ec mc IIC T4 Gc
Ex tc IIIC T82°C Dc
Ta = -20 °C to +55 °C
IP66 IP67

Marking Continued:

BL**




Ex ec mc IIC T4 Gc

Ex tc IIIC T98°C Dc

Ta = - 50 °C to +55 °C

IP66 IP67

BL Emergency**



Ex ec mc IIC T4 Gc


Ex tc IIIC T98°C Dc

Ta = -20 °C to +55 °C

IP66 IP67

Certified Sockets Fitted (except type GHG 54):**

FL** and FL** Emergency




Ex dc ec mc IIC T4 Gc

Ex tb IIIC T82°C Db

Ta = See below

BL** and BL** Emergency




Ex dc ec mc IIC T4 Gc

Ex tb IIIC T98°C Db

Ta = See below

Certified Socket type GHG 54 fitted:**


FL** and FL** Emergency



Ex dc ec mc IIC T4 Gc

Ta = See below

BL** and BL** Emergency



Ex dc ec mc IIC T4 Gc

Ta = See below

A certified socket may be fitted as an option. The upper and lower ambient temperature ranges will be limited by the type of certified socket fitted as shown below and within the ambient temperature range of the equipment shown above.

FL or BL** (excluding FL** Emergency or BL** Emergency)**

Sockets type fitted:

PCX/EN 16A

Ta = -20 °C to +40 °C

GHG 54*** 16A

Ta = -20 °C to +40 °C

GHG 5118*** 16A (Latest)

Ta = -50 °C to +40 °C

GHG 5118*** 16A

Ta = -20 °C to +40 °C

8572/15-***-

Ta = -50 °C to +40 °C

8573/15-***-

Ta = -50 °C to +45 °C

FL Emergency or BL** Emergency**

Any socket type fitted

Ta = -20 °C to +40 °C

All of the marking above is applicable for when the Spartan Power Supply or Universal Power Supply is used.

11 Description

The Spartan SPZ Floodlight/Bulkhead Luminaire is a range of LED lighting.

The enclosures are constructed using front, centre, and rear cast aluminium housings fixed using bolts. The front housing has a soda lime toughened glass lens available in clear or coloured options. A 'Vario' holographic diffuser film may be fitted behind the glass to give alternative light patterns. An optional replaceable antistatic lens film may be fitted.

The centre housing has either 1 or 2 independent encapsulated power supplies (electronic control gear) and terminal blocks for supply and internal connections. LED's are mounted on one or two independent Insulated Metal Substrate (IMS) PCBs attached to rear heat sink. Each PCB has 12 LED's that are either white, infra-red, coloured or a combination. Alternatively LED's are mounted on a single IMS PCB attached to rear heat sink with 96 LED's (arranged in 6 x clusters of 16 LED's) that are either white, infra-red, coloured or a combination. An EMC filter module may be fitted as an optional extra, this is an additional encapsulated board, located in place of the terminal block bracket (when fitted).

The front and middle/rear housing of the luminaires may be split to allow the LED assembly to be mounted remotely from the power supply/emergency enclosure. There are internal and external earth points.

The following variant types are available:

Fixed (FL)	Fixed installation with above construction for use with mounting bracket. Fixing points are used for mounting bracket for fixing in any orientation and for additional mounting accessories.
Bulkhead (BL)	Wall mounting in any orientation using rear mounted steel brackets. The enclosure uses a modified FL variant light engine and has reduced height enclosure that houses a single power supply.
Transportable (FLT and BLT)	Fixed (FL) or Bulkhead (BL) luminaires mounted in tubular frame with suitable cable and separately certified gland, plugs and sockets.
Portable (FLP and BLP)	Fixed (FL) or Bulkhead (BL) luminaires mounted in tubular frame with suitable cable and separately certified glands and, plugs and sockets.
Fixed Emergency (FL ..-EM)	Medium Fixed (FL) Floodlight with extended rear housing incorporating an additional rechargeable battery pack, connection terminal block and encapsulated fuse
Bulkhead Emergency (BL ..-EM)	Medium Bulkhead (BL) incorporating a rechargeable battery pack, connection terminal block and encapsulated fuse.

The variants are available in the following configurations:

***12	Small Floodlight
***24	Medium Floodlight

***48	Large Floodlight (2 x Medium FL24 fitted together horizontally or vertically with unions and alternative support brackets).
***72	Extra Large Floodlight (3 x Medium FL24 fitted together horizontally or vertically with unions and alternative support brackets).
Where *** = FL, BL, FLT, BLT, FLP or BLP variant and 12, 24, 48 and 72 are total the number of LED's	

All variants may be fitted with an optional encapsulated photocell. The EM variants may be fitted with a battery indicator LED.

Cable entries are provided for connection of the electrical supply for use with suitably certified cable glands. Alternatively, optional separately certified sockets of the following types may be mounted onto the back of an alternate luminaire enclosure and the certified ambient range of the equipment is limited to that of the type of socket fitted. When sockets are mounted onto the portable variants, they are fitted with an essential carrying frame.

Description	Ambient Range	Certification Code		Socket Certificate Numbers	
		Gas	Dust	ATEX	IECEX
ATX Appleton PC//EN Socket	-20°C to +40°C	II 2 G Ex db e mb IIC	II 2 D Ex tD A21 IP66	LCIE 02ATEX0001U	IECEX LCI 07.0012U
Cooper CH GHG 54** Socket	-20°C to +40°C	II 2 G Ex db eb IIC	N/A	BVS 14ATEXE131U	IECEX BVS 14.0089U
Cooper CH GHG 5118	-50°C to +40°C	II 2 G Ex db eb IIC	II 2 D Ex tb IIIC Db	BVS 15ATEXE101U	IECEX BVS 15.0088U
Cooper CH GHG 5118	-20°C to +40°C	II 2 G Ex db e mb IIC	N/A	PTB 99ATEX1040U	IECEX BKI 04.0002
Stahl 8572/15-***.*	-50°C to +45°C	II 2 G Ex db eb IIC Gb	II 2 D Ex tb IIIC Db	PTB 16ATEX1016U	IECEX PTB 16.0028U
Stahl 8573/15-***.*	-50°C to +40°C	II 2 G Ex db eb IIC Gb	II 2 D Ex tb IIIC Db	PTB 16ATEX1018U	IECEX PTB 16.0030U

When used, the equipment ambient temperature range will be limited to the type of socket fitted.

The enclosures are available with the following power supply:

HV (High Voltage);	110 to 280 Vac / 154 to 355 Vdc
Universal Power Supply	110V – 254V AC or DC
Extended Input Voltage Universal Power Supply	110 to 277 V AC or DC

DALI dimmable Universal Power Supply	110 to 277 V AC or DC
--------------------------------------	-----------------------

The following power supplies are available as options:

LV (Low Voltage);	18 to 48 Vac / 18 to 69 Vdc
ELV (Extra Low Voltage) rated	12 Vac/ Vdc

The following certification codes are used for the different power supply options:

Code	Description	Ambient Range (No Certified Sockets fitted)	Certification Code		
			FL ** and BL **	FL **	BL **
HV	High Voltage 110 to 280 Vac 154 to 355 Vdc 110V – 254V AC or DC 110 to 277 V AC or DC	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4	II 3 D Ex tc IIIC T82°C	II 3 D Ex tc IIIC T98°C
LV	Low Voltage 18 to 48 Vac, 18 to 69 Vdc	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4	II 3 D Ex tc IIIC T82°C	II 3 D Ex tc IIIC T98°C
ELV	Extra Low Voltage 12 Vac/ 12 Vdc	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4	II 3 D Ex tc IIIC T82°C	II 3 D Ex tc IIIC T98°C
HV-...-EM	High Voltage 110 to 280 Vac 154 to 355 Vdc Emergency Variants with Battery Pack	-20 °C to +55 °C	II 3 G Ex ec mc IIC T4	II 3 D Ex tc IIIC T82°C	II 3 D Ex tc IIIC T98°C

Code	Description	Ambient Range (No Certified Sockets fitted)	Certification Code		Mounting Frame Required
FL12	Fixed Lighting - Small Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	NO
FL24	Fixed Lighting - Medium Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	NO
FL48	Fixed Lighting - Large Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	NO
FL72	Fixed Lighting - Extra Large Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	NO
BL24	Fixed Lighting - Small Bulkhead	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T98°C Dc	NO
FLT12	Transportable Lighting - Small Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	NO
FLT24	Transportable Lighting - Medium Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	NO
FLT48	Transportable Lighting - Large Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	YES
FLT72	Transportable Lighting - Extra Large Floodlight	-50°C to +55°C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	YES
BLT24	Transportable Lighting - Small Bulkhead	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T98°C Dc	NO
FLP12	Portable Lighting Small Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	NO
FLP24	Portable Lighting - Medium Floodlight	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	NO
BLP24	Portable Lighting - Small Bulkhead	-50 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T98°C Dc	NO
FL24- ..-EM	Fixed Lighting - Emergency Floodlight	-20 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T82°C Dc	YES

Code	Description	Ambient Range (No Certified Sockets fitted)	Certification Code		Mounting Frame Required
BL24- ..-EM	Fixed Lighting - Bulkhead Emergency	-20 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T98°C Dc	YES
FL24- ..-LV	Fixed Lighting - Low Voltage	-20 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T98°C Dc	YES
BL24- ..-LV	Fixed Lighting - Bulkhead Low Voltage	-20 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T98°C Dc	YES
FL24- ..-ELV	Fixed Lighting - Extra Low Voltage	-20 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T98°C Dc	YES
BL24- ..-ELV	Fixed Lighting - Bulkhead Extra Low Voltage	-20 °C to +55 °C	II 3 G Ex ec mc IIC T4 Gc	II 3 D Ex tc IIIC T98°C Dc	YES

Variation 1

This variation introduces the following modifications:

- i. To assess the Universal Power Supply.
- ii. To assess the High Output variant of the Spartan LED Linear Luminaires.
- iii. To update and review the equipment against the latest standards: EN IEC 60079-0:2018/ IEC 60079-0:2017 Ed. 7 and EN IEC 60079-7:2015+A1:2018/ IEC60079-7:2017 Ed. 5.1.
- iv. To correct UKEX standard references.
- v. To correct UKEX Conditions of Manufacturer.

Variation 2

This variation introduces the following modifications:

- i. Assessment of Extended Input Voltage Universal PSU.
- ii. Assessment of DALI Dimmable Universal PSU.
- iii. CML 21UKEX4106, Issue 2 was reverted back to a Type Examination Certificate. Issue 1 was mistakenly issued as a Type Examination Certificate.

Variation 3

This variation introduces the following modifications:

- i. To introduce an alternate light engine.

12 Certificate history and evaluation reports

Issue	Date	Associated Report	Notes
0	26 Mar 2021	R13817A/00	Issue of Prime Certification
1	02 Sep 2022	R15050A/00	Introduction of Variation 1
2	16 Apr 2024	R17429A/00	Introduction of Variation 2
3	06 Dec 2024	R17815A/00	Introduction of Variation 3

Note: Drawings that describe the equipment are listed or referred to in the Annex.

13 Conditions of Manufacture

- i. Where the product incorporates certified parts or safety critical components the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate. A copy of the certificate and instructions for each separately certified part installed within the equipment shall be provided as part of the document pack with each arrangement supplied.
- ii. The manufacturer shall fit only the certified Ex Components listed in the Equipment Description in accordance with the certification documentation and the manufacturer's ratings and instructions. All Special Conditions of Certification/ Special Conditions for Safe Use/ Schedule of Limitations must be satisfied for each part fitted.
- iii. A dielectric strength test shall be carried out on all units manufactured in accordance with IEC 60079-7:2015 clause 7.1 and IEC 60079-18:2014, clause 9.2, at 1560 Vac for 1 minute, or alternatively at 1.2 times this test voltage for 100 ms. Alternatively, a 1.4 times d.c. voltage dielectric strength test may be carried out. No breakdown shall occur.
 - Tests shall be carried out between each circuit and earth and between each circuit and the surface of encapsulated parts.
- iv. A visual inspection shall be carried out on the encapsulated parts to check for damage, in accordance with IEC 60079-18:2014, clause 9.1.
- v. Alternative nameplates marked with "op is" are also acceptable.
- vi. When fitted with universal PSU module, equipment shall only be marked T4 for Gb applications.

Any routine tests/verifications required by the ATEX certification shall be conducted.

14 Specific Conditions of Use

None.

Certificate Annex

Certificate Number CML 17ATEX4231 Issue 3
Equipment Spartan SPZ Floodlight/Bulkhead Luminaire
Manufacturer Raytec Ltd



The following documents describe the equipment defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved Date	Title
1180-SD-0001	1 of 4	C	26 Mar 2021	SPARTAN LED ZONE 2 FLOODLIGHT
1180-SD-0001	2 of 4	B	26 Mar 2021	SPARTAN LED ZONE 2 FLOODLIGHT
1180-SD-0002	1 of 3	C	26 Mar 2021	SPARTAN BULKHEAD – ZONE 2
1080-SD-0002	2 of 3	B	26 Mar 2021	SPARTAN BULKHEAD – ZONE 2

Issue 1

Drawing No.	Sheets	Rev	Approved Date	Title
910-SD-00061	1 of 1	A	24 Aug 2022	ALTERNATIVE UNIVERSAL OUTPUT POWER SUPPLY FOR FL AND BL PRODUCT RANGES
1180-SD-0001	2 of 4	C	24 Aug 2022	SPARTAN LED ZONE 2 FLOODLIGHT Ex nA
1080-SD-0002	2 of 3	C	24 Aug 2022	SPARTAN BULKHEAD – ZONE 2

Issue 2

#	Drawing No.	Sheets	Rev	Approved Date	Title
01	1180-SD-0001	1 to 5	D	16 Apr 2024	SPARTAN LED ZONE 2 FLOODLIGHT Ex nA
02	1180-SD-0002	1 to 3	D	16 Apr 2024	SPARTAN BULKHEAD - ZONE 2

Issue 3

#	Drawing No.	Sheets	Rev	Approved Date	Title
01	940-SD-0001	1 of 1	H	06 Dec 2024	SPARTAN BULKHEAD
02	940-SD-0001	1 of 1	G	06 Dec 2024	SPARTAN BULKHEAD
03	940-SD-0001	1 of 1	H	06 Dec 2024	SPARTAN BULKHEAD
04	940-SD-0001	1 of 1	B	06 Dec 2024	SPARTAN BULKHEAD