



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX FIDI 21.009X** Page 1 of 4 Certificate history:  
Status: **Current** Issue No: 2 [Issue 1 \(2024-09-27\)](#)  
[Issue 0 \(2022-06-14\)](#)  
Date of Issue: 2025-05-08  
Applicant: **Pepperl+Fuchs SE**  
Lilienthalstrasse 200  
68307 Mannheim  
Germany  
Equipment: **Isolated barrier type: KFD0-SD2-Ex\* and KFD2-SLD-Ex\***  
Optional accessory:  
Type of Protection: **Intrinsic safety 'ia'; Increased safety 'ec'**  
Marking: Ex ec [ia Ga] IIC T4 Gc  
[Ex ia Da] IIIC  
[Ex ia Ma] I

Approved for issue on behalf of the IECEx  
Certification Body:

**Marino Kelava**

Position:

**Certification Signatory**

Signature:  
(for printed version)

Date:  
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**Fiditas Ltd**  
Slavka Tomerlina 44  
Zagreb-Sesvete HR-10361  
Croatia



**Fiditas**  
explosion safety solutions



# IECEX Certificate of Conformity

Certificate No.: **IECEX FIDI 21.0009X**

Page 2 of 4

Date of issue: 2025-05-08

Issue No: 2

Manufacturer: **Pepperl+Fuchs SE**  
Lilienthalstrasse 200  
68307 Mannheim  
Germany

Manufacturing locations: **Pepperl+Fuchs Asia Pte. Ltd.**  
18 Ayer Rajah Crescent  
Singapore 139942  
Singapore

**Pepperl+Fuchs Co. Ltd.**  
Lot S 12-16a  
Street 20 Tan Thuan EPZ  
Ward Tan Thuan Dong, District 7  
Ho Chi Minh City  
Viet Nam

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

#### STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

[IEC 60079-11:2011](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition:6.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[HR/FIDI/ExTR21.0014/00](#)

Quality Assessment Report:

[HR/FIDI/QAR24.0001/00](#)



# IECEX Certificate of Conformity

Certificate No.: **IECEX FIDI 21.0009X**

Page 3 of 4

Date of issue: 2025-05-08

Issue No: 2

## EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Isolated barriers are used for intrinsic safety applications. They supply power to solenoids, LEDs and audible alarms located in a hazardous area. These devices are controlled with a loop powered signal or a bus powered logic signal.

The devices are designed as associated apparatuses and can be installed in the non-hazardous area or in areas requiring EPL Gc equipment. The devices are associated apparatuses for areas requiring EPL Ga, Da or Ma equipment.

The voltage and current at the output terminals are limited to intrinsically safe levels. The hazardous area circuits are galvanically isolated from all other circuits up to a peak value of 375 V.

## Type designation

KFD0-SD2-Ex#.1045\*

KFD0-SD2-Ex#.1245\*

KFD0-SD2-Ex#.1545\*

KFD2-SLD-Ex#.1045\*

KFD2-SLD-Ex#.1245\*

KFD2-SLD-Ex#.1545\*

"#" = "1" or "2" depending on the number of channels

"\*" = "-Y" followed by numeric signs (e.g. -Y1). This "\*" is optional and is used to describe different versions of a module. These differences do not affect intrinsic safety.

For details see Annex of this certificate.

## SPECIFIC CONDITIONS OF USE: YES as shown below:

- The device must be installed and operated only in a controlled environment that ensures a pollution degree 2 (or better) according to IEC 60664-1.
- The device must be installed and operated only in an environment of overvoltage category II (or better) according to IEC 60664-1.
- Additional requirements for installation in areas requiring Equipment Protection Level Gc:

The device must be installed and operated only in the surrounding enclosure that

- complies with the requirements for surrounding enclosures according to IEC 60079-0,
- is rated with the degree of protection IP54 according to IEC 60529.



# IECEX Certificate of Conformity

Certificate No.: **IECEX FIDI 21.0009X**

Page 4 of 4

Date of issue: 2025-05-08

Issue No: 2

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)**

Update of new QAR reference HR/FIDI/QAR24.0001/00.

**Annex:**

[IECEXFIDI21.0009X\\_02\\_P+F Barrier Annex1.pdf](#)

## General product information – continued from the body certificate

### Non-intrinsically safe circuits:

#### Inputs (all types):

Connection: Terminals 7, 8 for Channel 1 and Terminals 8, 9 for Channel 2  
Rated Voltage: 0...30 V DC  
Maximum Voltage  $U_m$ : 253 V

#### Power Supply (only KFD2-SLD-Ex\*):

Connection: Terminals 14 and 15 resp. Power Rail contacts  
Rated Voltage: 18 ...30 V DC  
Maximum Voltage  $U_m$ : 253 V

#### Collective error messaging (only KFD2-SLD-Ex\*):

Connection: Power Rail contact PR4  
Maximum Voltage  $U_m$ : 253 V

### Intrinsically safe circuits:

#### Output circuits:

Connection: Terminals 1, 2, 3 for Channel 1 and Terminals 4, 5, 6 for Channel 2

KFD0-SD2-Ex1.1045\*, KFD0-SD2-Ex2.1045\*,  
KFD2-SLD-Ex1.1045\*, KFD2-SLD-Ex2.1045\*:

Maximum values per channel:

$U_0$	= 25.2 V
$I_0$	= 93 mA
$P_0$	= 586 mW
Characteristic:	linear
$C_i$	= negligible
$L_i$	= negligible

Type of protection	Ex ia resp. ib			
	I	IIA	IIB/IIIC	IIC
Maximum permissible external inductance $L_0$	53.95 mH	32.88 mH	16.44 mH	4.11 mH
Maximum permissible external capacitance $C_0$	4.15 $\mu$ F	2.9 $\mu$ F	820 nF	107 nF
Maximum L/R ratio	796 $\mu$ H/ $\Omega$	485 $\mu$ H/ $\Omega$	242 $\mu$ H/ $\Omega$	60 $\mu$ H/ $\Omega$

#### Note:

The above parameters of capacitance and inductance apply when one of the two conditions below is met:

- The total  $L_i$  of the external circuit (excluding the cable) is < 1 % of the  $L_0$  value or
- The total  $C_i$  of the external circuit (excluding the cable) is < 1 % of the  $C_0$  value.

The above parameters for capacitance and inductance are reduced to 50 % when both of the two conditions below are met:

- the total  $L_i$  of the external circuit (excluding the cable) is  $\geq$  1 % of the  $L_0$  value and
- the total  $C_i$  of the external circuit (excluding the cable) is  $\geq$  1 % of the  $C_0$  value.

The reduced capacitance of the external circuit (including cable) shall not be greater than 1 $\mu$ F for I, IIA.

KFD0-SD2-Ex1.1245\*, KFD0-SD2-Ex2.1245\*,  
KFD2-SLD-Ex1.1245\*, KFD2-SLD-Ex2.1245\*:

Maximum values per channel:

$U_0$	= 25.2 V
$I_0$	= 110 mA
$P_0$	= 693 mW
Characteristic:	linear
$C_i$	= negligible
$L_i$	= negligible

Type of protection	Ex ia resp. ib			
	I	IIA	IIB/IIIC	IIC
Maximum permissible external inductance $L_0$	38.56 mH	23.5 mH	11.75 mH	2.93 mH
Maximum permissible external capacitance $C_0$	4.15 $\mu$ F	2.9 $\mu$ F	820 nF	107 nF
Maximum L/R ratio	673 $\mu$ H/ $\Omega$	410 $\mu$ H/ $\Omega$	205 $\mu$ H/ $\Omega$	51 $\mu$ H/ $\Omega$

**Note:**

The above parameters of capacitance and inductance apply when one of the two conditions below is met:

- The total  $L_i$  of the external circuit (excluding the cable) is < 1 % of the  $L_0$  value or
- The total  $C_i$  of the external circuit (excluding the cable) is < 1 % of the  $C_0$  value.

The above parameters for capacitance and inductance are reduced to 50 % when both of the two conditions below are met:

- the total  $L_i$  of the external circuit (excluding the cable) is  $\geq$  1 % of the  $L_0$  value and
- the total  $C_i$  of the external circuit (excluding the cable) is  $\geq$  1 % of the  $C_0$  value.

The reduced capacitance of the external circuit (including cable) shall not be greater than 1 $\mu$ F for I, IIA.

KFD0-SD2-Ex1.1545\*, KFD0-SD2-Ex2.1545\*,  
KFD2-SLD-Ex1.1545\*, KFD2-SLD-Ex2.1545\*:

Maximum values per channel:	$U_0$	= 25.2 V	or alternatively:	$U_0$	= 25.2 V
	$I_0$	= 52 mA		$I_0$	= 153 mA
	$P_0$	= 850 mW		$P_0$	= 960 mW
	$R_i$	= 167 $\Omega$		Characteristic:	linear
	Characteristic:	angular		$C_i$	= negligible
	$C_i$	= negligible		$L_i$	= negligible
	$L_i$	= negligible			

Type of protection (valid for angular and linear characteristic)	Ex ia resp. ib			
	I	IIA	IIB/IIIC	IIC
Maximum permissible external inductance $L_0$	19.4 mH	11.8 mH	5.9 mH	1.2 mH
Maximum permissible external capacitance $C_0$	4.15 $\mu$ F	2.9 $\mu$ F	820 nF	107 nF
Maximum L/R ratio	486 $\mu$ H/ $\Omega$	296 $\mu$ H/ $\Omega$	148 $\mu$ H/ $\Omega$	37 $\mu$ H/ $\Omega$



# IECEX Certificate of Conformity

IECEX FIDI 21.0009X, issue: 2  
Annex 1  
Date: 2025.05.08

**Note:**

The above parameters of capacitance and inductance apply when one of the two conditions below is met:

- The total Li of the external circuit (excluding the cable) is < 1 % of the Lo value or
- The total Ci of the external circuit (excluding the cable) is < 1 % of the Co value.

The above parameters for capacitance and inductance are reduced to 50 % when both of the two conditions below are met:

- the total Li of the external circuit (excluding the cable) is  $\geq 1$  % of the Lo value and
- the total Ci of the external circuit (excluding the cable) is  $\geq 1$  % of the Co value.

The reduced capacitance of the external circuit (including cable) shall not be greater than 1 $\mu$ F for I, IIA

**Rated data:**

Single channel versions: Tamb = -40°C to +70°C

Dual channel versions: Tamb = -40°C to +60°C / +70°C

(extended ambient temperature range up to 70 °C, refer to the manual for necessary mounting conditions)

KFD2-SLD-Ex2.1545 both switches set to bus powered: - 40°C to + 70°C

Ingress protection: IP20